

燃油（气）燃烧器型式试验证书

Type Testing Certificate for Oil/Gas Burner

证书编号/Certificate No. : TSX B1000120140084

制 造 单 位 Manufacturer	利雅路热能设备（上海）有限公司（Riello Heating Equipment (Shanghai) Co. Ltd.）
单 位 地 址 Manufacturer Address	上海市金山区金山工业区金百路 388 号（No. 388 JinBai Road, JinShan Industrial Zone, Shanghai）
燃 烧 器 名 称 Name of Burner	燃油燃烧器
燃 烧 器 型 号 Model of Burner	RL44MZ
燃 烧 器 类 别 Classification of Burner	燃油燃烧器
试 验 报 告 书 编 号 Type Testing Report No.	14XF042-XR05

经试验，确认符合《燃油（气）燃烧器安全技术规则》的规定，主要配件见附件。 / Has been examined to be in accordance with the *Safety Technical Regulation for Oil and Gas Burners*. The list of main accessories is attached overleaf.

中国特种设备检测研究院
China Special Equipment Inspection and Research Institute

发证日期 / Issue Date: 2014年07月04日

注/note:

1. 本证书有效期4年 / This certificate is valid for four years after the issue date.
2. 本证书是对所明确覆盖范围内设备型式的确认，仅对样品本身试验时的合格与否负责 / This certificate is a type approval for the specified burner and the result is only responsible for the testing sample.
3. 证书持有者有责任保证产品符合标准规定和保证产品与型式试验样品的一致性 / The certificate holder shall take responsibilities to ensure that the products can satisfy the relevant regulations, and keep the products conform to the testing sample.

附件：主要配件表 / attachment: list of main accessories

配件名称	型号	主要参数	制造单位名称
程序控制器	RMO88.53C2	230V, 50/60Hz,TSA5s	SIEMENS
点火变压器	TD2STCAF	2×12kV, 30mA	BRAHMA
火焰监测器	FC13	65-123kΩ	BRAHMA
安全切断阀 (燃油)	2895223	230V, 50/60Hz, IP54	RIELLO
油泵	7233-4AN67C	Pmax25bar	SUNTEC
风机电机	RHY110	230V, 50Hz, 420W, 2800rpm	RIELLO
伺服马达	液压油缸	/	/
电源	/	230V,50Hz	/